Annual Drinking Water Quality Report

Caroline Acres MHP, Maryland
PWSID #0050204
June 5, 2018

We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

The source of our drinking water is three wells drilled into the Piney Point aquifer, which lies about 400 feet below the earth's surface. An aquifer is an underground body of water, which is tapped by drilling wells and pumping the water to the surface for distribution. The 400 feet of earth between surface sources and this aquifer helps to purify the water before it actually reaches the aquifer, making it easier for us to treat before we pump it into your water distribution system.

We are pleased to report that our drinking water is safe and meets Federal and State requirements. The following report is provided in compliance with Federal regulations and will be provided annually each year. This report outlines the quality of our finished drinking water and what that quality means.

If you have any questions about this report or concerning your water utility, please contact the Park Manager, at (410) 482-6627**.** We want our valued customers to be informed about their water utility. If you want to learn more, please contact the Park Manager for an appointment

The Caroline MHP water department routinely monitors for contaminants in your drinking water according to Federal and State laws. The tables on the following pages show the results of our monitoring for the period of January 1st to December 31st, 2017**.** As water travels over the land or underground it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances.

This is an alert about your drinking water and a cosmetic dental problem that might affect children under nine years of age. At low levels, fluoride can help prevent cavities, but children drinking water containing more than 2 milligrams per liter of fluoride may develop cosmetic discoloration of their permanent teeth. The drinking water provided by your community water system. Caroline Acres has a fluoride of 2.17 mg/L. Dental fluorosis, in its moderate or severe forms, may result in a brown staining and or pitting of the permanent teeth. This problem occurs only in developing teeth, before they erupt from the gums. Children under nine should be provided with an alternative source of drinking water or water that has been treated to remove the fluoride to avoid the possibility of staining and pitting of their permanent teeth you may also want to contact your dentist about proper use by young children of the fluoride-containing products. Older children and adults may safely drink the water. Drinking water containing 4 mg/L of fluoride can increase your risk of developing bone disease. Your drinking water does not contain 4 mg/L of fluoride but were required to notify you when we discover that the fluoride levels in your drinking water exceed 2 mg/L because of this cosmetic dental problem.

Please call our office if you have questions.

Caroline Acres (Atlantic Realty Management, Inc) is dedicated to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Caroline Acres MHP
Atlantic Realty Management, Inc.
16886 Henderson Road
Henderson, Maryland 21640
Phone (410) 482-6627

Annual Drinking Water Quality Report

CAROLINE ACRES MOBILE HOME PARK

MD0050204

Annual Water Quality Report for the period of January 1 to December 31, 2017

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by CAROLINE ACRES MOBILE HOME PARK is Ground Water

For more information regarding this report contact:

Name Park Manager

Phone 410-482-6627

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

Source Water Information

Source Water Name		Type of Water	Report Status	Location
CAROLINE ACRES 1 CO700065	CO700065	GW	Y	NEAR 0 MI HENDERSON APPROX. 250 FT W OF MD 311
CAROLINE ACRES 2 CO680041	CO680041	GW	Y	HENDERSON
CAROLINE ACRES 3 CO920135	CO920135	GW	Y	T OF HENDERSON APPROX. 400 FT W OF 311

2017 Regulated Contaminants Detected

Water Quality Test Results

Definitions:	The following tables contain scientific terms and measures, some of which may require explanation.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
mrem:	millirems per year (a measure of radiation absorbed by the body)
na:	not applicable.
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine		0.3	0.3 - 0.3	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)		2.44	2.44 - 2.44	No goal for the total	60	ppb	N	By-product of drinking water disinfection
Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future								
Haloacetic Acids (HAA5)		2.44	2.44 - 2.44	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future								
Haloacetic Acids (HAA5)*		2.44	2.44 - 2.44	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future								
Total Trihalomethanes (TTHM)		3.6	3.6 - 3.6	No goal for the total	80	ppb	N	By-product of drinking water disinfection
Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future								
Total Trihalomethanes (TTHM)		3.6	3.6 - 3.6	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future								

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Fluoride	04/06/2015	2.09	2.09 - 2.09	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters		7.7	7.7 - 7.7	0	50	pCi/L	N	Decay of natural and man-made deposits.